


Quality of Water in the Vaal Barrage Reservoir

Date Sampled 17 June 2020



Interpretation of the results obtained from water samples collected at the respective sample points (refer map above).

Escherichia coli (E.coli) Predicted symptoms include: Skin irritations, infections & intestinal disorders*	E.coli counts per 100ml at sample points									
	1	2	3	4	5	6	7	8	9	10
	This Week	50	35	980	8,570	13,140	770	29	2,790	23,820
Last Week	99	22	488	2,420	6,020	79	3	641	77,010	4
Guideline	Low risk of gastrointestinal disorders <i>E.coli</i> < 130 counts/100ml			Slight risk of gastrointestinal disorders <i>E.coli</i> 130 - 200 counts/100ml		Significant risk of gastrointestinal disorders <i>E.coli</i> 200 - 400 counts/100ml			High risk of gastrointestinal disorders <i>E.coli</i> > 400 counts/100ml	

Blue Green Algae Predicted symptoms include: Skin irritations, infections & intestinal disorders*	Blue Green algae counts at sample points									
	1	2	3	4	5	6	7	8	9	10
	This Week	201	205	40	121	241	< 40	241	362	804
Last Week	161	40	80	603	161	965	241	603	< 40	110
Guideline	Low Risk Blue Green algae < 20,000 cells/ml			Moderate Risk Blue Green algae 20,000 – 100,000 cells/ml			High Risk Blue Green algae > 100,000 cells/ml			

Algal Pigments Predicted nuisance conditions include: Scums & smells	Algal pigments expressed as Chlorophyll-a levels at sample points									
	1	2	3	4	5	6	7	8	9	10
	This Week	2	< 2	2	2	9	9	23	102	15
Last Week	1	4	7	2	6	10	28	165	10	37
Guideline	Low Risk Chlorophyll-a < 15ug/l			Moderate Risk Chlorophyll-a 15 - 30ug/l			High Risk Chlorophyll-a > 30ug/l			

* If ingested. X Sample not received / no data available. Reports generated every Friday of the year.

DISCLAIMER: Although Rand Water has made every endeavour to make an accurate assessment of the parameters described above (based on published South African and international criteria), neither Rand Water, nor any of its officials, shall be responsible for any damage or health related problems that may result due to the use of the Vaal Barrage Reservoir for any purpose. The values reported are only an indicator of water quality, and low numbers are no guarantee of safe water.